

CERTIFICATE

Anbotek

Product Safety

CERTIFICATE

Of Conformity

Low Voltage Directive 2014/35/EU

Registration No.: AT78230SC400003

Report No.: 78230SC40000301

Applicant : SEGURIMAX INDÚSTRIA, IMPORTADORA E EXPORTADORA LTDA

Address : Rua Margarida Zimmermann,222-Bela Vista-Gaspar-SC-Brazil
CEP:89111-094

Product : Fire alarm control panel

Model No. : MAXPRO 500L (500 endereços), MAXPRO 1000L (1000 endereços)

Trade Mark : 

Rating : Input: 100-240V~, 0.23A,60-50Hz, ≤100W
Output: 24VDC, 5.2A

Test Standards : EN IEC 62368-1:2020+A11:2020

The certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical report and documentation are at the applicant's disposal. This is to certify that the tested sample is in conformity with Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. The certificate does not imply assessment of the series-production of the product. The applicant of the certificate is authorized to use this certificate in connection with EU declaration of conformity specified in Article 15 and Annex IV of the Directive.

May. 08, 2024
Date



Jason Xia
Jason Xia



The CE Marking may only be used if all relevant and effective EU Directives are complied with



Hunan Anbotek Compliance Laboratory Limited
101, Building 37, Liandong Yougu Industrial Park, No. 32, Yulian Road, Xueshi Street,
Yuelu District, Changsha, Hunan, China
Tel: (86)755-26066440
Http://www.anbotek.com

Fax: (86)755-26014772
Email:service@anbotek.com

